

**Government of Bihar
Public Health Engineering Department**

DISTRICT :- SAMASTIPUR			DIVISION :- SAMASTIPUR										MONTH:-MARCH 2026		
S.N.	BLOCK	VILLAGE	LOCATION OF SOURCE	PARAMETERS											REMARKS
				pH	TURB	EC	TDS	TH	Ca	Cl	Mg	Alka.	Fe	T.COL	
1	SAMASTIPUR	HARPUR AILOUTH	ST. PAUL SR. SEC. SCHOOL	7.1	1	86	56	38	12	16	8	45	0.1	-Ve	
Acceptable Limit as per BIS 10500/2012				6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	250mg/l	30 mg/l	200 mg/l	1.0mg/l	-	-
Permissible Limit* in Absence of Alternate source as per BIS 10500/2012				NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	1000 mg/l	100 mg/l	600 mg/l	NR	-	-

Soni
13/03/26
Chemist / Lab Assistant
P.H. Division Samastipur



Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 385

Dated: 19/03/2026

It is certified that an inspection team headed by Vishwanathan Kumar Mandal (Asst. Engg.)

(Name of Officers with designation) from P.W.D. Samastipur PHED

inspected the St. Paul Sr. Secondary School, Harpur Ailouth, Mushroighan, Samastipur.

(Name & Address of the school) on 13/03/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. PHED/384/26 dated 19/03/2026

of P.W.D. Samastipur (PHED Lab) certified that the

St. Paul Sr. Secondary School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 18/03/2027

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : P.W.D. Samastipur

19/3/26
ASSISTANT ENGINEER
PH DIVISION
SAMASTIPUR

To The Principal
St. Paul Sr. Sec. School,
(Name & Address of the Institution)
Harpur Ailouth, Samastipur.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies